Shenzhen Nore Testing Center Co.,Ltd.
South, No.1, Building 10, Maqueling Industrial Zone,
Nanshan Shenzhen, Guangdong, 518057, China
TEL: +86-755-33525266 FAX: +86-755-23004002
www.ntc-c.com



CERTIFICATE OF CONFORMITY

Low Voltage Directive 2014/35/EU

Registration No.: NTC1912801SV00

Applicant : Foshan Unipower Electronic Co., Ltd

Address : Block7, No.115, 1st ZhangCha Road, Foshan, Guangdong Province,

P.R.China

Manufacturer : Foshan Unipower Electronic Co., Ltd

Address : Block7, No.115, 1st ZhangCha Road, Foshan, Guangdong Province,

P.R.China

Factory : Foshan Unipower Electronic Co., Ltd

Address : Block7, No.115, 1st ZhangCha Road, Foshan, Guangdong Province,

P.R.China

Product Name : UPS

Brand Name : N/A

Identification: Model No.: \$600, \$800, \$1000

Rating : Input: 220-240Vac, 50/60Hz, 1Φ, 6.3A(for S1000), 5A(for

S800), 4A(for S1000)

Output: 220-240Vac, 50/60Hz, 1Φ, 1000VA/600W(for S1000), 800VA/480W(for 800), 600VA/360(for

S600)

Test Report No. : NTC1912801SV00

Standard : EN 62040-1: 2008+A1:2013





The certificate of conformity is based on an evaluation of a sample of the above-mentioned product. Technical report and documentation are at the applicant's disposal. This is to certify that the tested sample is in conformity with all provisions of Annex I of Council Directive 2014/35/EU, referred to the Low Voltage Directive. The certificate does not imply assessment of the production and does not permit the use of Lab's logo.